

OPEN FLAME ROOFING PERMIT REQUIREMENTS

1. The site must be cleared of all combustible materials prior to the start of the operation.
2. Contact Reno Dispatch at 334-2306 to notify them of actual job start time.
3. A 10 pound dry chemical ABC type fire extinguisher must be on site. The extinguisher must have a current tag with the State of Nevada seal.
4. Propane tank size shall be limited to 5 gallons.
5. A fire watch with attendant must be provided during the open flame operation
6. Fire watch shall check the attic spaces for a possible fire for a minimum of 30 minutes after the operation.

Additional requirements are subject to inspection and review of the operation.